

Sliptest Victoria Pty Ltd Accreditation Number 19858 3 Treboryn Crt, Rowville, 3178, VIC, Rowville, VIC, 3178 gary@sliptest.com.au 1300 SLIPTEST (1300 754 783)

Seamless Overlays - X Bond Natural Shield / Microcement

28 Jan 2021

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Accredited for Compliance with ISO/IEC 17025 - Testing - Accreditation Number 19858

Date Tested:	28 Jan 2021
Test Report Number:	2801212
Client Name & Address:	Seamless Overlays - 329 Darebin Road Thornbury VIC 3071
Test Tile / Project :	X Bond Natural Shield / Microcement
Surface / Product Tested :	X Bond Natural Shield / Microcement
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	22
Fixed / Unfixed Test :	Yes - Tested in the Direction of Anticipated Pedestrian Traffic
Testing Officer :	Gary Wiltshire
Testing Officer Signature	Ghalle 2

Test Results :

	Mean BPN of last 3 swings :	Image of Surface
Specimen 1	29	
Specimen 2	22	

Seamless Overlays - X Bond Natural Shield / Microcement

	Mean BPN of last 3 swings :	Image of Surface
Specimen 3	25	
Specimen 4	28	
Specimen 5	24	

Mean BPN Slip Resistance Value (SRV)

Using Slider 96 (4S) you have achieved a BPN of P2 = 25 - 34

Accredited for Compliance with ISO/IEC 17025 - Testing The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.Customer is responsible for the accuracy,completeness and regulatory compliance of all information about products provided to Sliptest Victoria PTY LTD pursuant to this test report.

Page 1 of 1 - END OF REPORT.

Page 2